
GROWATT MICROINVERTER CONFIGURATION QUICK CHECK LIST


Single System on Balcony / Roof



GROWATT MICROINVERTER CONFIGURATION QUICK CHECK LIST

Multiple System on Roof

MULTIPLE SYSTEM WITHOUT BATTERY



Microinverter		NEO 600/800/1000M-X(LoRa)
Connection from microinverter to grid	Solution 1	AC Bus Cable (AWG 10, 40A) / AC Bus Cable (AWG 12, 30A) (Including 20pcs AC Trunk Connectors, 40m)
(Choose 1 of 2)	Solution 2	AC Trunk Connector + AC cable (Client self-supply)
Datalogger		ShineWeLink (up to 5 devices)
Extension Cable from panel to micinverter/battery (Opt)		PV Extension Cable (1m)
Replacement of PV Connector (Opt)		PV Connector (Including PV +/- Connectors)
Cap1 (Integrated)		PV terminal dust plug
Cap2 (opt)		AC Trunk Port Cap
СарЗ		AC Trunk End Cap
Connector Unlock Too	ol (Opt)	AC Connector Unlock Tool PV Connector Unlock Tool AC Trunk Connector Unlock Tool

2-5pcs 【NEO 1000M-X(LoRa)】:

1 1pcs [AC Bus Cable (AWG 12/10)] + 1pcs [ShineWeLink] + 1pcs [AC Trunk End Cap]

2 2-5pcs [AC Trunk Connector] + 1pcs [ShineWeLink] + 1pcs [AC Trunk End Cap]

Configuration formula